

Reserve
1.933
Su 63

UNITED STATES DEPARTMENT OF AGRICULTURE
Rural Electrification Administration
Washington 25, D. C.

TECHNICAL STANDARDS COMMITTEES
Month of October 1950

The following is a summary of the changes in the "List of Materials Acceptable For Use on REA-Financed Systems" resulting from decisions of the Technical Standards Committees during the month of October 1950:

1. Page D p-1a - Connectors, Copper & Copperweld Copper, Connections to same size conductors or smaller

Add Burndy catalog number UC8W26L-AC for connections to guy strand.

2. Page D p-2a - Connectors, ACSR to ACSR

Add Joslyn catalog number J3044 for 4/0 and 3/0 bare conductors.

Add Burndy catalog number UC33RL-A to replace number UC2W28L-A for size No. 4 ACSR conductor over armor rods.

3. Page D z - Anchors, Expanding and Plate

Remove Locke catalog number C-8410 as a 12,000-pound expanding anchor on page "D z-2."

Add Locke catalog numbers on page "D z-2" as follows:

Holding Power in Sand - lbs.	6000	8000	10000	12000
------------------------------	------	------	-------	-------

<u>Manufacturer</u>	<u>Type</u>	<u>Catalog No.</u>
Locke	8 Way	C88100 C88115 C88135 C88135

Remove Porcelain Products catalog numbers C826, C846, C84, C8410, C1110, C1125, and C1140 on page "D z-3."

4. Page D av - Conductors, service (weatherproof)

Add Copperweld Steel catalog number URC-101 as follows:

<u>Manufacturer</u>	<u>MHD Copper Triple-braid(URC)</u>
Copperweld Steel	URC-101

5. Page D bi - Gain, Pole

Add Joslyn catalog number J4092.

2-Technical Standards Committees

Materials List Changes - Month of October 1950

6. Page D co - Secondary Fuses, Cutouts

Add General Electric catalog number 9F13A to replace number 9F13B.

7. Page D gg - Meter Protector

Add new page "D gg" attached to this summary.

gg - Meter Protector

(This item is to be used only with the approval of the Regional Construction Engineer where recurrent meter failure due to lightning is experienced.)

Manufacturer

General Electric

Catalog No.

9LA15A4

